

## **Mundelein Fire Department Extinguisher Requirements**

- A 10lb ABC fire extinguisher is required by each exit then 75' of travel distance after that.
- A CO2 extinguisher is required in all data and electrical rooms
- A class "K" extinguisher is required in all commercial kitchens
- A 2 ½ lb extinguisher is required on all torch carts
- A hood and duct system is required on new commercial kitchen

**If you need further information please email**

**[fdbureau@mundelein.org](mailto:fdbureau@mundelein.org)**

**They will get back to you as soon as possible**