

Mundelein Fire Department General Requirements

- The Village of Mundelein has adopted the 2006 IFC with amendments
- Fire alarm shall be installed on all new construction or change of occupancy class
- Sprinkler system is required on all new construction or if addition or alteration occurs and it calls for it in the 2006 IFC
- A 10lb fire extinguisher is required by each exit door and then 75' of travel after that
- A Knox box is required on all buildings with a fire alarm or sprinkler system, they can be ordered at www.knoxbox.com more may be required depending on the size of the building
- Address numbers shall be posted on the front and rear of the building
- Fire lanes are required to be 18' wide and are designated by the Mundelein Fire Prevention Bureau and enforced by the Mundelein Police Department
- Fire hydrants shall be spaced 300' apart
- PDF's of building floor plans are required to be sent to the Fire Prevention Bureau for preplan purposes

If you need further information please email

fdbureau@mundelein.org

They will get back to you as soon as possible