

Mundelein Fire Department Sprinkler Requirements

- Required on all new construction
- Must be designed Licensed Engineer
- Must be installed by State Licensed Sprinkler Contractor
- Three set of prints are required
- There is a plan review fee, of \$100.00, plus \$1.00 per head.
- 13R required on all new condos, apartments, and townhomes
- We do allow Blazemaster in basements, if the proper construction has been done
- FDC to be 5" Storz, with Knox locking cap and 30 degree elbow, locking cap can be purchased online at www.knoxbox.com
- FDC shall be located on the front of the building
- Outside strobe is required instead of bell
- Call ahead 24 to 48 hours for test

If you need further information please email

fdbureau@mundelein.org

They will get back to you as soon as possible