

## **Mundelein Fire Department Standpipe Requirements**

- Required on all buildings with a floor level over 30'
- Required on all buildings where a hose lay of 200' either vertically or horizontally may be required to reach the fire
- We do not require hose cabinets
- A Class 1 system shall be installed
- The system shall produce 100psi at the top floor
- The system shall produce 500gpm from the first discharge and then 250gpm and the following to a max of 1000gpm
- The discharges shall be installed on the intermediate level unless otherwise directed by the Mundelein Fire Department
- The Mundelein Fire Prevention Bureau will witness an acceptance test
- A plan review fee of \$75.00 applies

**If you need further information please email**

**[fdbureau@mundelein.org](mailto:fdbureau@mundelein.org)**

**They will get back to you as soon as possible**